

## CITRUS COUNTY BUILDING DIVISION

### NOTICE

**JULY 13, 2010**

To: A/C Contractors; mechanical contractors, general, building and residential contractors; owner/builders; interested parties

From: The Citrus County Building Division

Subj: "Matched" Equipment

---

As you know, the most recent code cycle adoption included new criteria to be met when changing out air conditioning equipment, specifically geared toward energy efficiency. One of the changes requires that outdoor and indoor units (ie condensing equipment and air handlers), that are not **designed** to be operated together must meet the U.S. Department of Energy certification requirements.

Matched systems are required. The match may be verified by any one of the following means:

- ARI (AHRI) data
- An Accredited Laboratory (ie ARL)
- A letter from the equipment manufacturer
- A letter from an engineer registered in the State of Florida

Please be advised that our inspectors will be checking for compliance with the matched equipment requirement on all A/C change-outs permitted on or after **August 9<sup>th</sup>**, which should provide ample time to address any outstanding contracts.